

कार्यालय
अभिषासि जमियन
निर्माण विभाग, इटावा
महाराष्ट्र

BUILDING SAFETY CERTIFICATE

No. 113/05/11/25

Dated: 05/05/2025

It is certified that the existing building **Suditi Global Academy**
at **.Vicharpur, Nh-19., Agra Road, Etawah.**

Detail of Block(s) In school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	03	03	03			

The building is owned/occupied by **Gopal Shiksha Parishad (Suditi Global Academy)** have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of UPPWD on..03/05/2025 in the presence of and that the building/premises is fit for occupancy for running school with effect from 03/05/2025 for a period of 03 years in accordance

with rule and subject to compliance of the specific conditions as appended.

1. Two doors in every class room with a size of wide 1.20 m & height 2.40 m minimum.
2. Fire Safety System working properly.
3. Minimum height of first floor terrace is 3.60 meter .
4. Teacher give training for students about fire protection.

Issued on 05/05/2025 at UPPWD ETAWAH by

[Handwritten Signature]

Signature with Seal :

Name :

Designation :

Name & Address of Department Office

[Handwritten Signature]
03/05/25
Gaurav Jain
A.E. (CIVIL)
निर्माण विभाग, इटावा
महाराष्ट्र